

9. A STAINLESS STEEL PORTABLE HOIST SOCKET, HALLIDAY PRODUCTS—SERIES DA, OR APPROVED EQUAL SHALL BE PROVIDED.
10. THE CONTROL PANEL FURNISHED SHALL BE AS RECOMMENDED BY THE PUMP MANUFACTURER AND ASSEMBLED IN ACCORDANCE WITH UL508. THE CONTROL SYSTEM SHALL INCLUDE, AT A MINIMUM, THE FOLLOWING: NEMA 3R STAINLESS STEEL ENCLOSURE, ALUMINUM INNER DOOR, ALTERNATOR RELAY AND TEST SWITCH, PUMP RUN INDICATOR LIGHTS, ELAPSED TIME METERS, LIGHTNING ARRESTOR, SURGE CAPACITOR, DUPLEX CONVENIENCE GFI RECEPTACLE, ALARM LIGHT AND AUDIBLE ALARM HORN. TYPE AND OF EMERGENCY GENERATOR RECEPTACLE SHALL BE COORDINATED WITH COMMISSION.
11. PUMP STATION SITE SHALL BE A MINIMUM OF 25'X25' AND SHALL BE FENCED. FENCING MUST BE A MINIMUM OF 6' HIGH AND SHALL INCLUDE A DOUBLE SWING GATE (MINIMUM 20' WIDE). A SIGN STATING "IN CASE OF EMERGENCY CALL 359-8373" SHALL BE FURNISHED AND ATTACHED TO THE FENCING. SIGN TO BE 12" WIDE BY 24" HIGH, WITH 2 1/2" LETTERS.
12. AN ALL WEATHER ROAD, MINIMUM OF 14' WIDE, CAPABLE OF SUPPORTING 36,000 POUND VEHICLES, MUST BE PROVIDED FOR ACCESS TO THE PUMP STATION SITE.
13. IF THE COMMISSION OWNS THE WATER SYSTEM IN THE AREA, THE DEVELOPER WILL BE RESPONSIBLE FOR EXTENDING A 3/4" WATER SERVICE TO THE PUMP STATION SITE. WATER SERVICE SHALL BE EQUIPPED WITH A SCDHEC APPROVED BACKLFW PREVENTION ASSEMBLY.
14. PUMP STATION SHALL BE EQUIPPED WITH TELEMETRY SYSTEM AS SPECIFIED.
15. CONTRACTOR MUST PROVIDE THE COMMISSION WITH A SPARE PUMP FOR LIFT STATION.

DATE: 4/29/94	REVISIONS	STANDARD DETAIL	LEXINGTON COUNTY JOINT MUNICIPAL WATER AND SEWER COMMISSION
SCALE: NTS		GENERAL NOTES	FILE NO. SP006F2