



CLASS B
COMPACTED GRANULAR BEDDING LOAD FACTOR 1.9

NOTES:

1. PIPE IS ASSUMED TO HAVE A MINIMUM COVER DEPTH OF 3'
2. BACKFILL MATERIALS SHALL BE FREE OF ROCKS OR LUMPS OVER 2" UP TO 12" ABOVE THE UTILITY BEING COVERED. NO ROCKS LARGER THAN 2" SHALL BE PERMITTED IN ANY OF THE FILL.
3. REFER TO JMWSC STANDARD SPECIFICATION – EXCAVATION, TRENCHING, AND BACKFILLING FOR UTILITIES.
4. REFER TO JMWSC STANDARD SPECIFICATION – GRAVITY SEWER

DATE: 10/1/2024	REVISIONS		STANDARD DETAIL		JOINT MUNICIPAL WATER AND SEWER COMMISSION
SCALE: NTS					
			STANDARD BEDDING DETAIL FOR PVC GRAVITY SEWER PIPE		FILE NO. SS004