



NOTE:

1. REFER TO JMWSC STANDARD SPECIFICATION: SANITARY SERVICE LATERAL CONNECTIONS.
2. FOR DEPTHS LESS THAN 10', PROVIDE SDR-35 PVC AND FOR DEPTHS GREATER THAN 10', PROVIDE SDR-26 PVC.
3. ALL FITTINGS SHALL BE GRAY IN COLOR. PROVIDE SDR-26 FITTINGS AT THE SERVICE TAP AND SDR-35 FITTINGS AT THE SERVICE CONNECTION (NEAR CLEANOUT). FITTINGS SHALL BE MANUFACTURED BY THE HARRINGTON COMPANY OR APPROVED EQUAL.
4. PROVIDE EPOXY COATED DUCTILE IRON SADDLE WITH 3" WIDE TYPE 304 STAINLESS STEEL STRAP AS MAUFACUTED BY FORD METER BOX OR APPROVED EQUAL. HOLE SHALL BE CORED IN PIPE TO ACCOMODATE SADDLE.
5. CLEANOUTS SHALL BE FLUSH WITH GRADE AND LOCATED OUTSIDE OF ALL PAVEMENT SURFACES INCLUDING DRIVEWAYS, SIDEWALKS, AND ROADWAYS.
6. WHEN SERVICE IS LOCATED BELOW ROAD, SERVICE LINE SHALL BE A MINIMUM OF 3' DEEP.
7. CLEANOUTS SHALL BE INSTALLED 2' TO 5' FROM COMMON PROPERTY LINE.

DATE: 10/1/2024	REVISIONS		STANDARD DETAIL		JOINT MUNICIPAL WATER AND SEWER COMMISSION
SCALE: NTS			SANITARY SERVICE LATERAL CONNECTION	FILE NO. SS005	