



NOTE:

1. SIZE MANHOLE TO PROVIDE A MINIMUM OF 12" OF CLEARANCE BETWEEN THE TOP OF THE ARV ASSEMBLY AND THE BOTTOM OF THE MANHOLE LID.
2. REFER TO JMWSC STANDARD SPECIFICATIONS - MANHOLES AND FORCE MAINS.
3. TRACER WIRE SHALL BE ACCESSIBLE FROM TOP OF MANHOLE.

DATE: 10/1/2024	REVISIONS	STANDARD DETAIL		JOINT MUNICIPAL WATER AND SEWER COMMISSION
SCALE: NTS		FORCE MAIN AIR RELEASE VALVE ASSEMBLY IN PRECAST MANHOLE		
			FILE NO.	SS006