


NOTES:

1. THE CONTRACTOR SHALL SUBMIT SHOP DRAWINGS TO DESIGN ENGINEER FOR APPROVAL. PROVIDE PRECAST CONCRETE STRUCTURE MATERIAL OR APPROVED EQUAL.
2. THE DESIGN ENGINEER SHALL SIZE THE GREASE TRAP FOR THE PROPOSED APPLICATION.
3. THE INVERT OF THE INLET PIPE SHALL NOT BE LESS THAN 2" ABOVE THE INVERT OF THE OUTLET PIPE.
4. THE BAFFLE WALL SHALL BE LOCATED 2/3 DISTANCE FROM THE INLET SIDE, FOR GREASE ACCUMULATION, AND 1/3 DISTANCE FROM OUTLET SIDE.

DATE: 10/1/2024	REVISIONS		STANDARD DETAIL		JOINT MUNICIPAL WATER AND SEWER COMMISSION
SCALE: NTS					
			PRECAST CONCRETE GREASE TRAP		FILE NO. SS007