


NOTES:

1. ABOVE GRADE PIPING SHALL BE SHOP PRIMED AND PAINTED PER JMWSC STANDARD SPECIFICATIONS.
2. PIPING SHALL BE SIZED TO MEET SINGLE PUMP DESIGN FLOW OF PUMP STATION.

DATE: 10/1/2024	REVISIONS		STANDARD DETAIL TYPICAL PUMP STATION PUMP BYPASS CONNECTION		JOINT MUNICIPAL WATER AND SEWER COMMISSION
SCALE: NTS					
					FILE NO. SS008E