



**NOTES:**

1. USE JCM # 406 FUSION EPOXY COATED SADDLE WITH DOUBLE STAINLESS STEEL STRAPS OR APPROVED EQUAL. SELECT SADDLE SIZE BASED UPON PIPE SIZE BEING TAPPED.
2. PLASTIC SERVICE PIPE AND TRACING WIRE SHALL HAVE CONTINUOUS RUN LENGTHS CONTAINING NO BREAKS OR JOINTS.
3. WHEN FORCE MAIN IS CROSSING BELOW A ROADWAY, A MINIMUM DEPTH OF 3' IS ALSO REQUIRED.
4. QUAZITE BOX HEIGHT SHALL BE DETERMINED BY FIELD CONDITIONS AND MINIMUM CLEARANCE OF PIPING AND FITTINGS. BOX SHALL BE SIZED TO ACCOMDATE SUFFICIENT SPACE FOR MAINTENANCE.
5. REFER TO JMWSC STANDARD SPECIFICATION - FORCE MAINS.

DATE: 10/1/2024	REVISIONS		STANDARD DETAIL		JOINT MUNICIPAL WATER AND SEWER COMMISSION
SCALE: NTS					
			2" FORCE MAIN TAPPING SLEEVE & VALVE		FILE NO. SS009