



NOTES:

1. PRIOR TO VALVE, WATER MAIN SHALL BE RESTRAINED FOR A MINIMUM DISTANCE OF 60 LINEAR FEET.
2. STIFFENERS WILL NEED TO BE INSTALLED IN EACH END. PROVIDE HARCO STIFFENER PT # 65-90480902 OR APPROVED EQUAL.

DATE: 10/1/2024	REVISIONS	STANDARD DETAIL		JOINT MUNICIPAL WATER AND SEWER COMMISSION
SCALE: NTS		POST TYPE HYDRANT BLOW-OFF FOR 4" WATER MAINS		
			FILE NO.	WL002