


NOTES:

1. FOR PVC PIPE: USE JCM # 406 COATED SADDLE WITH DOUBLE STAINLESS STEEL STRAPS OR APPROVED EQUAL. SELECT SADDLE SIZE BASED UPON PIPE SIZE BEING TAPPED AND TAP SIZE.
2. PLASTIC SERVICE PIPE AND TRACING WIRE SHALL HAVE CONTINUOUS RUN LENGTHS CONTAINING NO BREAKS OR JOINTS.

DATE: 10/1/2024	REVISIONS 	STANDARD DETAIL	 JOINT MUNICIPAL WATER AND SEWER COMMISSION
SCALE: NTS			
		2" WATER LINE BLOW-OFF DETAIL	FILE NO. WL003