



**NOTES:**

1. FOR PVC PIPE: USE JCM # 406 COATED SADDLE WITH DOUBLE STAINLESS STEEL STRAPS OR APPROVED EQUAL. SELECT SADDLE SIZE BASED UPON PIPE SIZE BEING TAPPED AND TAP SIZE.
2. FOR DUCTILE IRON PIPE: USE JCM # 408 COATED SADDLE WITH DOUBLE ELECTRO GALVANIZED STRAPS OR APPROVED EQUAL. SELECT SADDLE SIZE BASED UPON PIPE SIZE BEING TAPPED AND TAP SIZE.
3. PLASTIC SERVICE PIPE AND TRACING WIRE SHALL HAVE CONTINUOUS RUN LENGTHS CONTAINING NO BREAKS OR JOINTS.
4. WHERE 1" METER IS REQUIRED, PROVIDE TAPPING SADDLE FOR 1" TAP, 1" TUBING, 1" COUPLING, 1" CORPORATION VALVE, AND 1" CURB STOP WITH SAME MATERIALS AS SPECIFIED FOR 3/4" X 5/8".
5. WHEN SERVICE LINE IS CROSSING BELOW A ROADWAY, A MINIMUM DEPTH OF 3' IS REQUIRED.
6. REFER TO JMWSC STANDARD DETAIL WL006 FOR WATER METER CONNECTION PLAN.

DATE: 10/1/2024	REVISIONS		STANDARD DETAIL		JOINT MUNICIPAL WATER AND SEWER COMMISSION
SCALE: NTS					3/4" & 1" WATER SERVICE