



**NOTES:**

1. FOR PVC PIPE: USE JCM # 406 COATED SADDLE WITH DOUBLE STAINLESS STEEL STRAPS OR APPROVED EQUAL. SELECT SADDLE SIZE BASED UPON PIPE SIZE BEING TAPPED AND TAP SIZE.
2. FOR DUCTILE IRON PIPE: USE JCM # 408 COATED SADDLE WITH DOUBLE ELECTRO GALVANIZED STRAPS OR APPROVED EQUAL. SELECT SADDLE SIZE BASED UPON PIPE SIZE BEING TAPPED.
3. PLASTIC SERVICE PIPE AND TRACING WIRE SHALL HAVE CONTINUOUS RUN LENGTHS CONTAINING NO BREAKS OR JOINTS.
4. WHEN SERVICE LINE IS CROSSING BELOW A ROADWAY, A MINIMUM DEPTH OF 3' IS ALSO REQUIRED.
5. REFER TO JMWSC STANDARD DETAIL WL006 FOR WATER METER CONNECTION PLAN.
6. FOR WATER METERS LARGER THAN 2 INCHES, COORDINATE WITH JMWSC FOR DESIGN REQUIREMENTS AND REFER TO JMWSC STANDARD SPECIFICATION - WATER DISTRIBUTION PIPING.
7. PROVIDE STAINLESS STEEL O.D. CONTROLLED IPS INSERT STIFFENERS MODEL 6137 BY AY MCDONALD OR APPROVED EQUAL.

DATE: 10/1/2024	REVISIONS		STANDARD DETAIL		JOINT MUNICIPAL WATER AND SEWER COMMISSION
SCALE: NTS			2" WATER SERVICE		FILE NO. WL005