



NOTE:

1. SIZE MANHOLE TO PROVIDE A MINIMUM OF 12" OF CLEARANCE BETWEEN THE TOP OF THE ARV ASSEMBLY AND THE BOTTOM OF THE MANHOLE LID.
2. FOR MAINS LARGER THAN 12", ENGINEER TO PROVIDE ANALYSIS FOR AIR RELEASE/VACUUM LINE SIZING.
3. REFER TO JMWSC STANDARD SPECIFICATION – MANHOLES AND WATER UTILITY DISTRIBUTION PIPING.
4. TRACER WIRE SHALL BE ACCESSIBLE FROM TOP OF MANHOLE.

DATE: 10/1/2024	REVISIONS		STANDARD DETAIL		JOINT MUNICIPAL WATER AND SEWER COMMISSION
SCALE: NTS			WATER MAIN AIR RELEASE VALVE ASSEMBLY IN PRECAST MANHOLE		FILE NO. WL007