



NOTE:

1. REFER TO JMWSC STANDARD SPECIFICATIONS OF WATER DISTRIBUTION PIPING, GRAVITY SEWER, OR FORCE MAINS FOR INFORMATION PERTAINING TO CROSSING OF UTILITIES (PART 1.3 AND PART 3.2).
2. WATER AND SEWER CROSSINGS SHALL HAVE A MINIMUM VERTICAL SEPARATION OF 18".
3. WHERE VERTICAL SEPARATION ("a") IS LESS THAN 18", NEW WATER MAIN (OVER OR BELOW) SHALL BE SPACED SO JOINTS ARE SPACED AT 10' FROM THE CROSSING.
4. WHERE IT IS NOT PHYSICALLY POSSIBLE TO LOCATE SEWER BELOW A WATER MAIN, SEWER PIPE MUST BE FULLY ENCASED IN CONCRETE FOR A MINIMUM OF 10' ON EACH SIDE OF CROSSING.

DATE: 10/1/2024	REVISIONS		STANDARD DETAIL		JOINT MUNICIPAL WATER AND SEWER COMMISSION
SCALE: NTS			FERROUS MATERIALS AND JOINT REQUIREMENTS FOR WATER AND SEWER LINE CROSSING		FILE NO. WL008