



NOTES:

1. VALVES & BLOW-OFFS ARE NOT REQUIRED FOR CREEK CROSSINGS WITH BANK TO BANK DISTANCES LESS THAN 15' FEET.
2. DEPTH AND DESIGN SHALL BE BASED UPON CONSTRUCTION DRAWINGS. VALUES SHOWN ARE MINIMUM REQUIREMENTS IF NOT DIRECTLY SPECIFIED.

DATE: 10/1/2024	REVISIONS		STANDARD DETAIL		JOINT MUNICIPAL WATER AND SEWER COMMISSION
SCALE: NTS			STANDARD STREAM CROSSINGS (MIN. REQUIREMENTS, PIPES 12" AND BELOW)	FILE NO. WL010	